

January 4, 2022

Linda Ritter
City of Mukilteo
11930 Cyrus Way
Mukilteo, WA 98275



Received by Email

01/04/2022

Dear Ms. Ritter:


Ref: SD 2021 001/ENG 2021 019/SEPA 2021 010
Harbor Grove Subdivision Preliminary Plat

District DR Number: 21-10-384

The District presently has enough electric system capacity to serve the proposed development. However, the existing District facilities in the local area may require upgrading. Cost of any work, new or upgrade, to existing facilities that is required to connect this proposed development to the District electric system shall be in accordance with the applicable District policy. The developer will be required to supply the District with suitable locations/easements upon its property for any electrical facilities that must be installed to serve the proposed development. It is unlikely that easements will be granted on District-owned property, or consents granted within District transmission line corridors.

Please be advised that per WAC 296-24-960 the minimum worker safety clearance from any District distribution conductor is 10 feet. **Therefore, the District requires a minimum 14-foot clearance from any structure to accommodate workers, scaffolding and ladders. Minimum worker safety clearance from 115kV transmission wires is 20 feet.**

Any relocation, removal or undergrounding of District facilities to accommodate this project and the worker safety clearances shall be at the expense of the project developer and must be coordinated with the PUD in advance of final design. Please include any project related utility work in all applicable permits.





Providing quality water, power and service at a competitive price that our customers value

The District policy requires the developer to provide a minimum 10-foot easement for underground electrical facilities that must be installed to serve the proposed development. In addition, the developer must maintain an 8-foot clearance between transformers and a 10-foot clearance between switch cabinets and any building/structures upon its property. Additional clearances may be required depending on the equipment in the area and accessibility of the equipment.

Please contact the District prior to design of the proposed project. For information about specific electric service requirements, please call the District's Plat Development Team at (425) 783-4350.

Sincerely,

Mary Wicklund for

Mark Flury, Senior Manager
Transmission & Distribution System
Operations & Engineering

Cc: Jake Drake – jdrake@thebluelinegroup.com